

## **Currently known building deficiencies**

**Approved by Wilton Town Garage Committee on April 23, 2022**

- Quick run-down of the deficiencies are
- No room to expand or enlarge current building due to land constraints
- No ventilation for exhaust of vehicles inside the building
- No “break room” kitchenette for relaxation
- Wood stove used for heating
- No Fire Suppression System other than Fire Extinguishers
- No “Fire Resistant Chemical Cabinet” for Flammable Materials
- No space for vehicles with the plows mounted
- No space to wash the vehicles to maintain their use and longevity
- No room for the Grader to be stored inside
- Equipment stored outside will rust, being unable to wash, decreases the longevity of the equipment